



# JUNAGADH MUNICIPAL CORPORATION FIRE & EMERGENCY SERVICES

"SWAMI VIVEKANAND BHAVAN",  
AZAD CHOWK, JUNAGADH-362001  
PH.No. 0285-2622089, FAX No. 0285-2651510  
E-mail :municipalcorporationjund@yahoo.co.in

70  
आज़ादी का  
अमृत महोत्सव

J.M.C./Fire/Outword: 255 /2021

DT. 25-9-2021

## NO OBJECTION CERTIFICATE

This is to certify that the management of "Shree Swaminarayan Gurukul Gyanbag International School" Located at Sabalpur, Junagadh has provided adequate Fire Protection measures.

The Fire Department has NO OBJECTION to the said premises as required level of Fire Protection is provided as under;

### Fire Extinguishers

- 6 kg capacity ABC type Fire Extinguishers - (52 Nos)
- 4.5 kg capacity CO2 type Fire Extinguishers - (04 Nos)
- 6 kg capacity AFFF type Fire Extinguishers - (02 Nos)
- Fire Hydrant System

All Extinguishers / items shall be maintained in working order throughout the validity period of this certificate. (\* if you can't complete all works within 30 days which is suggested by fire officer, than this NOC is automatically be invalid.)

This Certificate is valid till 25-9-2023



1/c  
Fire Officer  
Junagadh Municipal Corporation



Principal  
S. S. Gurukul Gyanbag  
International School  
Sabalpur - Junagadh.